



Fibre Cement

BGC Stonesheet Fixing Guide

1 June 2007

Slip Weight	Wall Height	Stonesheet Type	Extra Requirements
20 to 40 kg m ²	Up to 2.7m	6.0mm Stonesheet	None – as per E2/AS1
	2.7 to 4 m	6.0mm Stonesheet	See Note 1
	Above 4 m	7.5mm Stonesheet	See Note 1
40 to 50 kg m	Up to 2.7m	6.0mm Stonesheet	See Note 1
	2.7 to 4 m	7.5mm Stonesheet	See Note 1
	Above 4m	7.5mm Stonesheet	Sheet Screw Fixed – see note 2
50 to 60 kg m ²	Up to 2.7m	7.5mm Stonesheet	Sheet Screw Fixed – see note 2
	2.7 to 4 m	7.5mm Stonesheet	Sheet Screw Fixed – see note 2
	Above 4 m	9.0mm Stonesheet	Sheet Screw Fixed – see note 2

Note 1. Fixing as per E2/AS1 plus replace nails on second nog line with screws and washers as per type below at 150mm centres

Note 2. Replace nails with screws and washers as per type below

Screw Type – MSL Fortress Fasteners 10g x 65mm Surefast Stainless Steel Screws

Washer Type – MSL Fortress Fasteners – m6 x 19mm x 1.6mm Stainless Steel Washer

E2/AS1 fixing requirements- table 24 – 60 x 3.15 Fibre Cement nail – 150mm centres to sides and 300mm Centres in middle

NOTE: Stonesheet™ is a non-structural substrate. BGC does not accept any responsibility for the selection and design of mechanical fixings and adhesives used.

Refer to your stone veneer supplier for details of mechanical and adhesive fixing requirements.

The Installation instructions and recommended kg/m² contained in the BGC Stonesheet™ Fixing Guide 1 June 2007 are supplied as a guide only.